

CERTIFICATE OF COMPLIANCE

Certificate Number 20171031-EX27504
Report Reference EX27504-20171031
Issue Date 2017-OCTOBER-31

Issued to: HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD
JALGAON Maharashtra 425003 INDIA

**This is to certify that
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES,
ASSEMBLED UNITS
Model Pre-Pack Cabinet (Pre-action and Deluge)
assembled units in the 2, 3, 4, 6 and 8 NPS valve riser
sizes.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 260, UL Standard For Safety For Dry Pipe and Deluge
Valves for Fire-Protection Service
UL 312, UL Standard for Safety for Check Valves for Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

