

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140610-EX5118  
**Report Reference** EX5118-19971203  
**Issue Date** 2014-JUNE-10

**Issued to:** HD FIRE PROTECT PVT LTD  
K-98, MIDC, AJANTA RD, JALGAON MH 425003 INDIA


**This is to certify that  
representative samples of** VALVES, ALARM  
See next page for Models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Safety For Alarm Valves for Fire-Protection Service, UL 193  
Guide for the Investigation of Alarm Valves for Fire-  
Protection Service, ULC C193

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140610-EX5118  
**Report Reference** EX5118-19971203  
**Issue Date** 2014-JUNE-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model A, 3, 4, 6 and 8 in. alarm valves for rated pressures of 175 psi with flanged ends for vertical installation only, may be provided with constant pressure trim or variable pressure trim for use with Model RA retard chamber and Model GA water motor gong.

Model H, 3, 4, 6 and 8 in. alarm valves for rated pressures of 250 psi with flanged ends for vertical installation only, may be provided with constant pressure trim or variable pressure trim for use with Model RC9 retard chamber and Model GA water motor gong, with the end connections: flanged-flanged, flanged-grooved and grooved-grooved.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)





# Certificate of Compliance

This certificate is issued for the following:

## Water Motor Gongs

Model GA, Type A.  
Model GA, Type B.

### Prepared for:

HD Fire Protect Pvt. Ltd.  
K-98 Ajanta Road  
Jalagon – 425 003  
India

### Manufactured at:

HD Fire Protect Pvt. Ltd.  
K-98 Ajanta Road  
Jalagon – 425 003  
India

FM Approvals Class: 1055, dated July 1970

Approval Identification: 0003040402      Approval Granted: April 26, 2012

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

*For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.*

A handwritten signature in black ink, appearing to read 'Richard B. Dunne', is written over a white rectangular background.

Richard B. Dunne  
Group Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*